



ADDENDUM No. 1
PROJECT: MOBILE ENERGY CLASSROOM
BID NO.: RFQ No. AVC2016/2017-3

Notice to Bidders on the Above Project:

This addendum consists of: **Bid clarifications**

Q-1. What are the specs for the student workstations? What is needed with the student workstations? Power? Ethernet? Etc.?

A-1. The District will provide and install computers, and AV equipment, based upon available space. This need can be withdrawn from the specification. From a design perspective - working space of a minimum of 30" wide per student station, 18" deep. A single of 20-amp circuit for the shelf of workstations will be sufficient, with two receptacles, below counter with 2, 2" grommets equally spaced at thirds through the surface. No networking/cabling is needed. Laminate surfaces are fine. Note: If you're going to put the workstations at a standing counter height or bar stool height, be sure to design one to comply with ADA/Wheelchair access height.

Q-2. What type of computers are needed for the student workstations?

A-2. The District will provide and install computers, and AV equipment, based upon available space. This need can be withdrawn from the specification.

Q-3. Any type of chairs/stools wanted for the student workstations?

A-3. The type of chairs/stools are at the discretion of the bidder. If you're going to put the workstations at a standing counter height or bar stool height, be sure to design one to comply with ADA/Wheelchair access height.

Q-4. What are you looking for with the Interactive audio/visual program?

A-4. The District will provide and install computers, and AV equipment, based upon available space. Item # 13 from the Mobile Energy Classroom Components section of the Scope of Work and Technical Specifications can be withdrawn from the specification.

All other terms and conditions remain the same.

Angela Musial
Angela Musial, Buyer

12/12/16
Date